

CHAPTER 5

Results Analysis and Discussion

5.1 Assessment of the existing power distribution systems up to 2013

From the data of existing networks and the results of load forecasting described in chapter 4, the peak load demand in 2011, 2012 and 2013 will be 268,659.37kW, 287,465.53kW and 333,460.01kW, respectively.

Use CYMDIST software to analyze load flow on the primary distribution networks of Vientiane capital in cases peak forecasted demands in 2013. Analysis results are shown in tables from 5.2.

5.2 Network elements

This research project has a situation that obtaining the specific detail, for CYMDIST, is very difficult. Because the project is located in the Vientiane capital and there are no complete data available for the Vientiane power distribution system and equipment even in distribution system. Therefore, the distribution transformers are not included in the simulation of the network. Also, some devices such as, fuses, re-closers, circuit breakers, switches, and etc are not included in the network simulation. Since the main point of the research is system's power loss and voltage drop in the MV level, the ignorance of the distribution transformers and protection devices do not have significant effect on the system simulation results.

For the feeders, as main factor causing power loss and voltage drop in the system, the zero sequence and negative sequence impedances and admittances and size of the conductors, used in CYMDIST, are collected for the system simulation. Table 5.1 shows bare conductors sizes used of the substations in the Vientiane capital electric network for overhead MV distribution lines. Similarly, contains specifications (Z_1 and B_1 are positive sequence impedance and susceptance respectively, Z_0 and B_0 are zero sequence impedance and susceptance respectively).

Table 5.1 Conductors specifications used for overhead lines of the Substations in Vientiane capital.

Equipment ID	Size (mm ²)	Z ₁ (Ω/km)		Z ₀ (Ω/km)		B0 (uS/km)	B1 (uS/km)	Rating (Amps)
		R1 (ohms/km)	X1 (ohms/km)	R0 (ohms/km)	X0 (ohms/km)			
ACSR	25	1.138	0.4818	1.3158	1.9333	1.49	3.45	145
ACSR	35	1.11	0.4129	1.2582	1.6397	1.26	2.97	126
ACSR	50	0.556	0.3912	0.7042	1.6180	1.29	3.15	190
ACSR	70	0.5560	0.3912	0.7042	1.6180	1.29	3.15	190
ACSR	150	0.1830	0.3281	0.3312	1.5550	1.34	3.47	335
ACSR	185	0.1882	0.3068	0.3364	1.5336	1.38	3.74	535
ACSR	240	0.1343	0.3179	0.2825	1.5448	1.36	3.60	560
PIC	35	0.826	0.4199	0.9742	1.6467	1.25	2.91	149
PIC	50	0.7831	0.3851	0.9313	1.6119	1.26	3.00	186
PIC	70	0.443	0.3733	0.5912	1.6001	1.28	3.09	237
PIC	95	0.3834	0.2844	0.5316	1.7472	0.90	2.27	279
PIC	120	0.253	0.3553	0.4012	1.5822	1.30	3.25	321
PIC	150	0.206	0.3432	0.3542	1.5700	1.31	3.31	365
PIC	185	0.164	0.3361	0.3122	1.5629	1.33	3.38	429
SAC	25	1.20	0.4302	1.3482	1.6570	1.23	2.84	120
SAC	35	0.868	0.4199	1.0162	1.6467	1.25	2.91	151
SAC	50	0.641	0.4085	0.7892	1.6354	1.26	3.00	187
SAC	70	0.443	0.3733	0.5912	1.6001	1.28	3.09	231
SAC	95	0.32	0.3631	0.4682	1.5899	1.29	3.18	281
SAC	120	0.253	0.3553	0.4012	1.5822	1.30	3.25	324
SAC	150	0.206	0.3492	0.3542	1.5761	1.31	3.31	375
SAC	185	0.164	0.3361	0.3122	1.5629	1.33	3.38	433
SAC	240	0.125	0.327	0.2732	1.5538	1.34	3.48	525

5.3 Medium voltage of Vientiane Capital

The MV system in Vientiane capital is composed of MSS system and MSH system. The MSS system composed of MV single circuit feeders with radial form are strung from directly from 115 kV / 22 kV substations or 22 kV switching stations to power supply areas. The MSH system is a system of interconnections among 115 kV / 22kV substations or 22kV switching station mainly with 240 mm² x 2 circuits.

5.4 Loads

The Vientiane capital substations and its associated junction stations serve a total of 2,535 distribution transformers that are considered as spot loads for the network simulation (including some of the inactive distribution transformers). As was mentioned in the first section of this chapter, the loads are composed of seven types: residential loads, governmental loads, office loads, industrial loads, agriculture load, embassy loads and business loads as seen in Appendix B.

Phonthong substation is 115kV/22kV, has four transformers and 4x30 MVA of size. It have six feeders, the name of feeders were MSS5.1, MSS5.2, MSS5.3, MSS5.4, MSS5.5 and MSS5.6.

Naxaythong substation is 115kV/22kV, has two transformers and 2x30 MVA of size. It have four feeders, the name of feeders were MSS10.1, MSS10.2, MSS10.3, MSS10.4.

Tha Ngon substation is 115kV/22kV, has two transformers and 2x30 MVA of size. It have four feeders, the name of feeders were MSS8.1, MSS8.2, MSS8.3, MSS8.4.

Koksa-at substation is 115kV/22kV, has two transformers and 2x30 MVA of size. It have six feeders, the name of feeders were MSS9.1, MSS9.2, MSS9.3, MSS9.4, MSS9.5 and MSS9.6.

Thanaleng substation is 115kV/22kV, has four transformers and 4x30 MVA of size. It have seven feeders, the name of feeders were MSS6.1, MSS6.2, MSS6.4, MSS6.5, MSS6.6, MSS6.7 and MSS6.8.

Sokphalaung substation is 22kV/22kV, It have six feeders, the name of feeders were MSS1.1, MSS1.2, MSS1.3, MSS1.4, MSS1.5 and MSS1.6.

Sisakhet substation is 22kV/22kV, It have six feeders, the name of feeders were MSS2.1, MSS2.2, MSS2.3, MSS2.4, MSS2.5 and MSS2.6.

Thatlaung substation is 22kV/22kV, It have four feeders, the name of feeders were MSS3.1, MSS3.2, MSS3.3 and MSS3.4.

Dongnasok substation is 22kV/22kV, It have four feeders, the name of feeders were MSS4.1, MSS4.2, MSS4.3 and MSS4.4.

5.5 2013 base case

The total peak loads of MSS system were 333,460.01kW and the total length was 1,416 km in case with situation in Vientiane capital. The loads are set capacities transformer. From data load (table 4.6) considering load of year for input to software analysis shown in Table 5.2. The total losses are 9,460.60kW.

Table 5.2 The result of losses calculation of MSS system on 2013

Name of substation	ID	Name of feeder	Total Load		Total Losses	Length
			kW	PF %	kW	km
Phonethong	1	MSS 5.1	14,268.4	88	230.3	9.8
	2	MSS 5.2	12,411.9	88	299.2	18.0
	3	MSS 5.3	12,295.8	86	342.5	29.6
	4	MSS 5.4	9,628.1	87	128.1	32.2
	5	MSS 5.5	3,480.0	88	5.8	6.1
	6	MSS 5.6	6,148.0	87	57.7	11.1

Table 5.2 The result of losses calculation of MSS system on 2013(Continued)

Name of substation	ID	Name of feeder	Total Load		Total Losses	Length
			kW	PF %	kW	km
Naxaythong	7	MSS10.1	1,044.0	88	2.3	18.3
	8	MSS10.2	8,236.1	87	326.7	97.5
	9	MSS10.3	7,716.6	86	1,191.9	200
	10	MSS10.4	4,961.0	87	25.9	24.9
Tha Ngon	11	MSS8.1	5,333.9	89	204.8	85.9
	12	MSS8.2	6,852.9	88	187.3	23.5
	13	MSS8.3	4,303.0	88	47.5	75.0
	14	MSS8.4	221.0	87	0.2	7.9
Koksa-at	15	MSS 9.1	6,737.0	87	128.1	26.0
	16	MSS 9.2	5,590.9	87	372.3	59.4
	17	MSS 9.3	14,996.5	84	2,099.9	205.8
	18	MSS 9.4	9,279.9	87	218.9	5.1
	19	MSS 9.5	3,969.0	87	16.8	1.1
	20	MSS 9.6	6,148.0	87	24.0	20.3
Thanaleng	21	MSS 6.1	7,887.9	88	222.8	14.2
	22	MSS 6.2	812.0	88	1.2	4.9
	23	MSS 6.4	7424.0	87	1.3	44.6
	24	MSS 6.5	6,148.1	88	82.2	86.3
	25	MSS 6.6	8,699.9	88	476	43.8
	26	MSS 6.7	10,915.1	87	410.7	21.3
	27	MSS 6.8	8,815.9	87	239.7	31.3
Sokphalaung	28	MSS 1.1	5,683.9	87	18.1	5.0
	29	MSS 1.2	7,540.0	87	51.7	11.0
	30	MSS 1.3	4,872.0	87	19.2	10.8
	31	MSS 1.4	1,771.0	87	0.7	1.9
	32	MSS 1.5	7,076.0	88	38.0	12.9
	33	MSS 1.6	6,727.9	88	15.8	6.7
Sisakhet	34	MSS2.1	8,699.8	88	29.2	3.9
	35	MSS2.2	7,496.9	87	18.1	3.8
	36	MSS2.3	4,524.0	87	5.5	2.7
	37	MSS2.4	1,624.0	88	0.2	0.3
	38	MSS2.5	4,175.9	87	12.8	13.2
	39	MSS2.6	9,280.0	87	53.1	10.7

Table 5.2 The result of losses calculation of MSS system on 2013(Continued)

Name of substation	ID	Name of feeder	Total Load		Total Losses	Length
			kW	PF %	kW	km
Thatlaung	40	MSS3.1	7,056.1	87	108.5	41.7
	41	MSS3.2	6,031.9	88	20.2	6.2
	42	MSS3.3	5,915.9	88	18.3	5.8
	43	MSS3.4	5,733.0	87	37.2	8.7
Dongnasok	44	MSS4.1	11,599.9	88	288.4	24.1
	45	MSS4.2	20,532.8	87	1,288.4	26.0
	46	MSS4.3	10,474.0	88	88.8	12.4
	47	MSS4.4	2,320.0	87	4.8	4.4
Total			333,460.0		9,460.6	1,416.1

5.6 2013 improved case

5.6.1 Load balancing

The load balancing analysis will determine which loads can be reconnected to different phases so as to minimize kW losses or balance the current or the load. It reports a series of individual changes to the network and the kW loss reduction with each change.

CYMDIST will run a voltage drop analysis for each change made. It then retains the change that reduces the losses the most or that balances the load or the current the best and repeats the whole process to find the subsequent change and so on. The process will continue until no change can further optimize the solution.

For example, if the load on a section were phase A is 40kVA, phase B is 48kVA and phase C is 62kVA, the average would be $150/3 = 50$ kVA. The unbalance factor would be 20% for phase A, 4% for phase B and 24% for phase C. the highest unbalance factor 24% is assigned to the section.

5.6.1.1 Result of load balancing in feeder MSS3.1 of Thatlaung substation

The analysis load balancing can process feeders MSS3.1 of Thatlaung substation.

Table 5.3 Parameters load balancing of Tatlaung substation

Objective:	Balance the load (KVA)
Minimum load:	1.00 KVA
Minimum unbalanced factor:	10.00 %
Include 1-phase section(s):	Yes
Include 2-phase section(s):	Yes
Include 3-phase section(s):	Yes
Ignore the underground cable:	Yes

Table 5.4 Recommended rephasing for location: feeder MSS3.1 (means applied by user)

Section ID	Rephasing (KVA)				Phase A	Phase B	Phase C	Losses	Average
	A	B	C		KVA	KVA	KVA	(KW)	KVA unbal.
S3_F1_290	to B 8.38		to A 8.32	Before	2,709.02	2,692.12	2,709.33	108.51	0.28 %
				After	2,709.16	2,700.91	2,700.39	108.50	0.14 %
S3_F1_285	to C 4.21		to B 4.19	Before	2,709.16	2,700.91	2,700.39	108.50	0.14 %
				After	2,704.75	2,705.41	2,700.31	108.50	0.08 %

Table 5.5 Feeder summary load balancing of Tatlaung substation

	Capacity MVA	Phase A KVA	Phase B KVA	Phase C KVA	Losses KW	Average KVA unbal.
Before	20.46	2,709.02	2,692.12	2,709.33	108.51	0.28 %
After	20.46	2,704.75	2,705.41	2,700.31	108.50	0.08 %
Savings losses					0.01	




Figure 5.1 Location of single phase loads in feeder MSS3.1

5.6.1.2 Result of load balancing in Tha Ngon substation

◆ Feeder MSS8.1

Table 5.6 Recommended rephasing for location : feeder MSS8.1 (means applied by user)

Section ID	Rephasing (KVA)				Phase A	Phase B	Phase C	Losses	Average
	A	B	C		KVA	KVA	KVA	KW	KVA unbal.
S8_F1_34	to B		to A	Before	2,000.28	1,991.96	2,000.76	204.76	0.19 %
	3.47		3.45	After	2,000.41	1,995.59	1,997.00	204.76	0.09 %

Table 5.7 Feeder summary of load balancing in Tha Ngon substation

	Capacity MVA	Phase A KVA	Phase B KVA	Phase C KVA	Losses KW	Average KVA unbal.
Before	13.06	2,000.28	1,991.96	2,000.76	204.76	0.19 %
After	13.06	2,000.41	1,995.59	1,997.00	204.76	0.09 %
Savings losses					0	




Figure 5.2 Location of single phase loads in feeder MSS8.1

◆ **Feeder MSS8.2**

Table 5.8 Recommended rephasing for location : feeder MSS8_2 (means applied by user)

Section ID	Rephasing (KVA)				Phase A	Phase B	Phase C	Losses	Average
	A	B	C		KVA	KVA	KVA	KW	KVA unbal.
S8_F2_46	to B		to A	Before	2,599.60	2,586.90	2,600.60	187.30	0.23 %
	4.06		4.06	After	2,599.90	2,591.30	2,596.00	187.29	0.11 %
S8_F2_288	to B		No	Before	2,599.90	2,591.30	2,596.00	187.29	0.11 %
	4.06		change	After	2,595.30	2,596.20	2,595.60	187.29	0.01 %

Table 5.9 Feeder summary of load balancing in feeder MSS8_2

	Capacity MVA	Phase A KVA	Phase B KVA	Phase C KVA	Losses KW	Average KVA unbal.
Before	13.06	2,599.67	2,586.95	2,600.68	187.30	0.23 %
After	13.06	2,595.35	2,596.27	2,595.67	187.29	0.01 %
Savings losses					0.01	




Figure 5.3 Location of single phase loads in feeder MSS8.2

◆ **Feeder MSS8.3**

Table 5.10 Recommended rephasing for location : feeder MSS8.3 (means applied by user)

Section ID	Rephasing (KVA)				Phase A	Phase B	Phase C	Losses	Average
	A	B	C		KVA	KVA	KVA	KW	KVA unbal.
S8_F3_137	to B		to A	Before	1,638.10	1,612.70	1,638.80	47.53	0.70 %
	5.42		5.42	After	1,638.40	1,618.50	1,632.80	47.53	0.47 %
S8_F3_205	to B		No	Before	1,638.40	1,618.50	1,632.80	47.53	0.47 %
	4.66		change	After	1,633.60	1,623.20	1,632.90	47.53	0.27 %
S8_F3_249	to B		No	Before	1,633.60	1,623.20	1,632.90	47.53	0.27 %
	4.76		change	After	1,628.70	1,628.20	1,632.80	47.53	0.12 %

Table 5.11 Feeder summary of load balancing feeder MSS8.3

	Capacity MVA	Phase A KVA	Phase B KVA	Phase C KVA	Losses KW	Average KVA unbal.
Before	13.06	1,638.10	1,612.70	1,638.80	47.53	0.70 %
After	13.06	1,628.70	1,628.20	1,632.80	47.53	0.12 %
Savings losses					0	




Figure 5.4 Location of single phase loads in feeder MSS8.3

5.6.1.3 Result of load balancing in Koksa-at substation

◆ Feeder MSS9.1

Table 5.12 Recommended rephasing for location : feeder MSS9.1 (means applied by user)

Section ID	Rephasing (KVA)				Phase A KVA	Phase B KVA	Phase C KVA	Losses KW	Average KVA unbal.
	A	B	C						
S9_F1_33	No change		to B 12.80	Before	2,589.40	2,561.80	2,591.10	128.05	0.49 %
				After	2,590.20	2,575.50	2,576.60	128.05	0.24 %

Table 5.13 Feeder summary of load balancing in feeder MSS9.1

	Capacity MVA	Phase A KVA	Phase B KVA	Phase C KVA	Losses KW	Average KVA unbal.
Before	13.06	2,589.40	2,561.80	2,591.10	128.05	0.49 %
After	13.06	2,590.20	2,575.50	2,576.60	128.05	0.24 %
Savings losses					0	




Figure 5.5 Location of single phase loads in feeder MSS9.1

◆ Feeder MSS9.2

Table 5.14 Recommended rephasing for location : feeder MSS9.2 (means applied by user)

Section ID	Rephasing (KVA)				Phase A	Phase B	Phase C	Losses	Average
	A	B	C		KVA	KVA	KVA	KW	KVA unbal.
S9_F2_276	No change		to B 12.10	Before	2,158.10	2,094.40	2,173.60	299.90	1.48 %
				After	2,162.70	2,111.10	2,152.00	299.75	0.96 %
S9_F2_114	to B 12.11		No change	Before	2,162.70	2,111.10	2,152.00	299.75	0.96 %
				After	2,146.90	2,130.10	2,148.60	299.67	0.37 %

Table 5.15 Feeder summary of load balancing in feeder MSS9.2

	Capacity (MVA)	Phase A (KVA)	Phase B (KVA)	Phase C (KVA)	Losses (KW)	Average KVA unbal.
Before	21.82	2,158.19	2,094.48	2,173.63	299.90	1.48 %
After	21.82	2,146.98	2,130.10	2,148.63	299.67	0.37 %
Savings losses					0.23	

◆Feeder MSS9.3

Table 5.16 Recommended rephasing for location : feeder MSS9_3 (means applied by user)

Section ID	Rephasing (KVA)				Phase A	Phase B	Phase C	Losses	Average
	A	B	C		KVA	KVA	KVA	KW	KVA unbal.
S9_F3_308	to B 8.5 5		No change	Before	6,100.00	5,706.40	6,115.70	2,099.90	2.99 %
				After	6,104.00	5,748.00	6,060.30	2,095.40	2.49 %
S9_F3_526	to B 8.5 5		No change	Before	6,104.00	5,748.00	6,060.30	2,095.40	2.49 %
				After	6,099.70	5,794.30	6,010.40	2,091.80	1.94 %
S9_F3_297	to B 8.5 2		No change	Before	6,099.70	5,794.30	6,010.40	2,091.80	1.94 %
				After	6,091.10	5,844.80	5,963.00	2,089.30	1.39 %
S9_F3_102	to B 4.1 5	to C 4.1 6		Before	6,091.10	5,844.80	5,963.00	2,089.30	1.39 %
				After	6,071.70	5,857.00	5,968.20	2,088.50	1.21 %
S9_F3_112	to B 6.2 3		No change	Before	6,071.70	5,857.00	5,968.20	2,088.50	1.21 %
				After	6,065.10	5,878.10	5,952.90	2,088.10	1.11 %
S9_F3_270	to B 5.1 3		No change	Before	6,065.10	5,878.10	5,952.90	2,088.10	1.11 %
				After	6,058.00	5,911.60	5,925.20	2,087.50	1.04 %
S9_F3_294	to B 5.1 2		No change	Before	6,058.00	5,911.60	5,925.20	2,087.50	1.04 %
				After	6,049.50	5,949.70	5,895.30	2,087.40	0.95 %
S9_F3_444	to C 5.1 0		to B 0.16	Before	6,049.50	5,949.70	5,895.30	2,087.40	0.95 %
				After	6,005.90	5,990.40	5,896.30	2,086.50	0.76 %

Table 5.17 Feeder summary of load balancing in feeder MSS9.3

	Capacity MVA	Phase A KVA	Phase B KVA	Phase C KVA	Losses KW	Average KVA unbal.
Before	21.82	6,100.00	5,706.40	6,115.70	2,099.90	2.99 %
After	21.82	6,005.90	5,990.40	5,896.30	2,086.50	0.76 %
Savings losses					13.4	

◆ **Feeder MSS9.4**

Table 5.18 Recommended rephasing for location : feeder MSS9_4 (means applied by user)

Section ID	Rephasing (KVA)				Phase A	Phase B	Phase C	Losses	Average
	A	B	C		KVA	KVA	KVA	KW	KVA unbal.
S9_F4_20	to B		to A	Before	3,591.40	3,478.80	3,596.30	218.80	1.44 %
	13.32		13.32	After	3,592.00	3,492.80	3,581.60	218.80	1.17 %
S9_F4_22	to B		No	Before	3,592.00	3,492.80	3,581.60	218.80	1.17 %
	13.32		change	After	3,577.90	3,507.50	3,581.00	218.80	0.90 %
S9_F4_24	to B		to A	Before	3,577.90	3,507.50	3,581.00	218.80	0.90 %
	13.32		13.32	After	3,578.50	3,521.50	3,566.30	218.80	0.64 %

Table 5.19 Feeder summary of load balancing in feeder MSS9.4

	Capacity MVA	Phase A KVA	Phase B KVA	Phase C KVA	Losses KW	Average KVA unbal.
Before	14.61	3,591.40	3,478.80	3,596.30	218.86	1.44 %
After	14.61	3,578.50	3,521.50	3,566.30	218.81	0.64 %
Savings losses					0.05	

5.6.1.4 Result of load balancing in Naxaythong substation

◆ **Feeder MSS10.2**

Table 5.20 Recommended rephasing for location: feeder MSS10.2 (means applied by user)

Section ID	Rephasing (KVA)				Phase A	Phase B	Phase C	Losses	Average
	A	B	C		KVA	KVA	KVA	KW	KVA unbal.
S10_2_159	to B		to A	Before	3,166.10	3,130.00	3,170.50	326.74	0.54 %
	7.56		7.56	After	3,167.20	3,138.80	3,160.70	326.73	0.35 %
S10_2_446	to B		No	Before	3,167.20	3,138.80	3,160.70	326.73	0.35 %
	6.28		change	After	3,159.40	3,147.50	3,159.60	326.71	0.17 %
S10_2_350	to B		to A	Before	3,159.40	3,147.50	3,159.60	326.71	0.17 %
	6.03		5.54	After	3,159.90	3,154.40	3,152.20	326.71	0.09 %

Table 5.21 Feeder summary load balancing in feeder MSS10.2

	Capacity (MVA)	Phase A (KVA)	Phase B (KVA)	Phase C (KVA)	Losses (KW)	Average KVA unbal.
Before	13.06	3,166.10	3,130.00	3,170.50	326.74	0.54 %
After	13.06	3,159.90	3,154.40	3,152.20	326.71	0.09 %
Savings losses					0.03	




Figure 5.6 Location of single phase loads in feeder MSS10.2

◆ **Feeder MSS10.3**

Table 5.22 Recommended rephasing for location : feeder MSS10_3 (means applied by user)

Section ID	Rephasing (KVA)				Phase A	Phase B	Phase C	Losses	Average
	A	B	C		KVA	KVA	KVA	KW	KVA unbal.
S10_3_566	No change		to B 9.86	Before	2,963.90	2,877.00	3,132.60	1,191.90	3.15 %
				After	3,001.30	2,892.40	3,071.50	1,187.00	2.14 %
S10_3_537	No change		to B 4.93	Before	3,001.30	2,892.40	3,071.30	1,187.00	2.14 %
				After	3,019.00	2,899.90	3,044.20	1,185.90	1.96 %
S10_3_632	No change		to B 4.92	Before	3,019.00	2,899.90	3,044.20	1,185.90	1.96 %
				After	3,037.30	2,907.40	3,017.50	1,185.40	1.79 %
S10_3_1236	to B 4.92		No change	Before	3,037.30	2,907.40	3,017.50	1,185.40	1.79 %
				After	3,027.30	2,930.80	3,002.20	1,184.40	1.25 %
S10_3_1017	to B 4.11		No change	Before	3,027.30	2,930.80	3,002.20	1,184.40	1.25 %
				After	3,019.20	2,950.90	2,989.60	1,184.00	0.80 %
S10_3_270	to B 4.93		No change	Before	3,019.20	2,950.90	2,989.60	1,184.00	0.80 %
				After	3,012.70	2,963.20	2,983.60	1,183.90	0.58 %
S10_3_296	to B 4.93		No change	Before	3,012.70	2,963.20	2,983.60	1,183.90	0.58 %
				After	3,005.90	2,976.70	2,976.90	1,183.90	0.43 %
S10_3_84	to C 4.88		to B 4.87	Before	3,005.90	2,976.70	2,976.90	1,183.90	0.43 %
				After	3,000.60	2,984.00	2,974.90	1,184.00	0.31 %

Table 5.23 Feeder summary of load balancing in feeder MSS 10.3

	Capacity MVA	Phase A KVA	Phase B KVA	Phase C KVA	Losses KW	Average KVA unbal.
Before	19.10	2,963.90	2,877.00	3,132.60	1,191.91	3.15 %
After	19.10	3,000.60	2,984.00	2,974.90	1,184.00	0.31 %
Savings losses					7.91	




Figure 5.7 Location of single phase loads in feeder MSS10.3

5.6.1.5 Summarize of load balancing in distribution system of Vientiane capital

The load balancing in CYMDIST program had calculated ten feeders. There are MSS3.1, MSS8.1, MSS8.3, MSS9.1, MSS9.2, MSS9.3, MSS9.4, MSS10.2 and MSS10.3. The results in above could summarize as seen table...

Table 5.24 Summarize load balancing of distribution system

Name of feeder	Capacity size (single phase)	Unit	Losses		Loss reduction	Average kVA unbalance	
			Before	After		Before	After
	kVA		kW	kW	kW	%	%
MSS3.1	30	2	108.51	108.50	0.01	0.28	0.08
MSS8.1	30	1	204.76	204.76	-	0.19	0.09
MSS8.2	30	2	187.30	187.29	0.01	0.23	0.01
MSS8.3	30	3	47.53	47.53	-	0.70	0.12
MSS9.1	30	1	128.05	128.05	-	0.49	0.24
MSS9.2	30	2	299.90	299.67	0.23	1.48	0.37
MSS9.3	30	8	2,099.95	2,086.55	13.40	2.99	0.76
MSS9.4	30	3	218.86	218.81	0.05	1.44	0.64
MSS10.2	30	3	326.74	326.71	0.03	0.54	0.09
MSS10.3	30	8	1,191.91	1,184.00	7.91	3.15	0.31
Losses reduction					21.64		

5.6.2 Optimal capacitor placement

The following data is required for the capacitor placement.

- Capacitor bank unit size (set 50 kVAR, 100kVAR and 200kVAR per phase).
- Loading conditions (3 step loading levels: light, normal and heavy load or peak load). CYMDIST is capable of calculating the appropriate amount of capacitor according to the loading level is shown in table 5.4. The loading level is determined by the required for the light load period, it can calculate the amount of capacitor for normal load and heavy load period as on-off switchable capacitor. In addition to the loading level setting, it must be determined how long each of 3 step loading level continues in a year. Desired power factor is also required.
- Process of capacitor placement by program, feeder loading on CYMDIST and select an objective function such as factor correction, loss reduction, and voltage rise, etc. capacitor bank selection so that program can choose the bank applied in the system. The setting of loading conditions so that program can indicate how much the fixed capacitor or switched capacitor required is shown in table 5.25

Table 5.25 Loading condition

Name of feeders	Light load			Normal load			Peak load		
	Loading	Desired power factor	Time at loading	Loading	Desired power factor	Time at loading	Loading	Desired power factor	Time at loading
	[%]	[%]	[% of Year]	[%]	[%]	[% of Year]	[%]	[%]	[% of Year]
MSS 5.1	33	98	40	49	98	42	80	98	18
MSS 5.2	42	98	26	56	98	52	75	98	22
MSS 5.3	20	98	35	45	98	44	75	98	21
MSS 5.4	27	98	32	45	98	44	75	98	21
MSS 5.5	19	98	33	30	98	45	61	98	22
MSS 5.6	20	98	38	60	98	41	80	98	21
MSS10.1	51	98	21	60	98	54	79	98	25
MSS10.2	51	98	21	60	98	54	79	98	25
MSS10.3	51	98	21	60	98	54	79	98	25
MSS10.4	51	98	21	60	98	54	79	98	25
MSS8.1	45	98	37	60	98	41	75	98	22
MSS8.2	42	98	24	77	98	59	85	98	17
MSS8.3	39	98	36	50	98	47	78	98	17
MSS8.4	11	98	11	20	98	66	53	98	23
MSS 9.1	20	98	39	41	98	41	81	98	20
MSS 9.2	28	98	29	46	98	51	78	98	20
MSS 9.3	40	98	19	60	98	57	80	98	24
MSS 9.4	30	98	25	49	98	54	70	98	21
MSS 9.5	32	98	38	49	98	44	70	98	18
MSS 9.6	32	98	33	64	98	49	85	98	18
MSS 6.1	20	98	22	44	98	57	74	98	21
MSS 6.2	18	98	26	20	98	54	35	98	20
MSS 6.4	39	98	29	53	98	50	70	98	21
MSS 6.5	23	98	37	49	98	43	70	98	20
MSS 6.6	23	98	29	47	98	50	72	98	21
MSS 6.7	38	98	31	63	98	45	75	98	24
MSS 6.8	39	98	32	66	98	42	78	98	26
MSS 1.1	35	98	27	54	98	57	78	98	16
MSS 1.2	32	98	24	67	98	56	85	98	20
MSS 1.3	36	98	31	62	98	51	82	98	18
MSS 1.4	45	98	16	70	98	65	86	98	19
MSS 1.5	49	98	26	68	98	51	80	98	23
MSS 1.6	50	98	16	69	98	61	86	98	23
MSS2.1	32	98	34	65	98	44	77	98	22
MSS2.2	20	98	28	50	98	56	83	98	16
MSS2.3	46	98	31	51	98	54	82	98	15
MSS2.4	57	98	48	71	98	33	86	98	19
MSS2.5	30	98	26	56	98	57	83	98	17
MSS2.6	30	98	35	50	98	42	70	98	23
MSS3.1	36	98	17	77	98	72	82	98	11
MSS3.2	35	98	14	67	98	66	79	98	20
MSS3.3	35	98	33	63	98	41	76	98	26
MSS3.4	41	98	27	61	98	54	75	98	19
MSS4.1	43	98	30	60	98	43	70	98	27
MSS4.2	56	98	22	69	98	53	75	98	25
MSS4.3	22	98	18	60	98	48	70	98	34
MSS4.4	25	98	15	40	98	67	50	98	18

5.6.2.1 Capacitor bank at 50 kVAR per phase

Table 5.26 Summarize result from program of capacitor bank 50kVAR

Name of substation	ID	Name of feeder	Total Loss	Capacitor placement			
			Before	Loss	Fixed	Switch	Savings Loss
			kW	kW	Unit	Unit	kW
Phonethong	1	MSS 5.1	230.30	188.70	12	14	41.50
	2	MSS 5.2	299.20	244.00	13	8	55.20
	3	MSS 5.3	342.50	264.50	6	18	78.00
	4	MSS 5.4	128.10	105.70	7	11	22.40
	5	MSS 5.5	5.80	5.30	1	3	0.40
	6	MSS 5.6	57.70	45.90	3	9	11.80
Naxaythong	7	MSS10.1	2.30	2.10	1		0.30
	8	MSS10.2	326.70	259.10	11	5	67.70
	9	MSS10.3	1,191.90	838.10	8	7	353.80
	10	MSS10.4	25.90	20.70	7	2	5.20
Tha Ngon	11	MSS8.1	204.80	168.00	5	3	36.80
	12	MSS8.2	187.30	149.80	7	6	37.50
	13	MSS8.3	47.50	39.20	3	4	8.30
	14	MSS8.4	0.20	0.20	-	-	-
Koksa-at	15	MSS 9.1	128.05	101.20	3	10	26.90
	16	MSS 9.2	372.26	288.00	2	8	11.90
	17	MSS 9.3	2099.88	1,506.90	12	19	593.10
	18	MSS 9.4	218.87	1.00	7	9	0.20
	19	MSS 9.5	16.75	4.60	4	6	4.90
	20	MSS 9.6	24.04	19.30	5	7	4.80
Thanaleng	21	MSS 6.1	222.80	184.40	3	10	38.40
	22	MSS 6.2	1.20	1.20	-	-	-
	23	MSS 6.4	1.30	1.00	-	1	0.20
	24	MSS 6.5	82.20	67.40	3	6	14.80
	25	MSS 6.6	476.00	402.00	4	9	73.90
	26	MSS 6.7	410.70	333.00	11	9	77.70
	27	MSS 6.8	239.70	187.60	9	8	52.10
Sokphalaung	28	MSS 1.1	18.10	14.20	5	6	3.80
	29	MSS 1.2	51.70	40.60	6	10	11.10
	30	MSS 1.3	19.20	15.10	5	5	4.10
	31	MSS 1.4	0.70	0.60	2	1	0.10
	32	MSS 1.5	38.00	31.30	9	4	6.70
	33	MSS 1.6	15.80	12.80	9	4	3.00

Table 5.26 Summarize result from program of capacitor bank 50kVAR(Continued)

Name of substation	ID	Name of feeder	Total Loss Before	Capacitor placement			
				Loss	Fixed	Switch	Savings Loss
			kW	kW	Unit	Unit	kW
Sisakhet	34	MSS2.1	29.20	23.80	7	8	5.40
	35	MSS2.2	18.10	14.40	4	11	3.70
	36	MSS2.3	5.50	4.40	5	4	1.10
	37	MSS2.4	0.20	0.10	2	1	0.10
	38	MSS2.5	12.80	10.10	3	5	2.60
	39	MSS2.6	53.10	42.80	7	9	10.30
Thatlaung	40	MSS3.1	108.50	86.00	6	8	22.50
	41	MSS3.2	20.20	16.60	5	6	3.60
	42	MSS3.3	18.30	15.10	5	5	3.20
	43	MSS3.4	37.20	30.10	6	4	7.10
Dongnasok	44	MSS4.1	288.40	239.10	12	6	49.30
	45	MSS4.2	1,288.40	1,026.80	32	7	261.60
	46	MSS4.3	88.80	73.20	6	10	15.60
	47	MSS4.4	4.80	4.20	1	1	0.60
Total			9,460.60	7,130.20	284	307	2,033.10

Table 5.26 can be summarized as following: the fixed capacitors bank installed 284 units, 300 kVAR per unit and 5.5 USD/ kVAR. The switched capacitors bank installed 307 units, 300 kVAR per unit and 10 USD/ kVAR. Total loss is 9,460.60 kW before installing capacitors bank and 7,130.20 kW after installing capacitors bank. It decreases 2,033.10 kW.




Figure 5.8 Location of capacitor bank of Sokpalaung substation

5.6.2.2 Capacitor bank at 100 kVAR per phase

Table 5.27 Summarize result from program of capacitor bank 100kVAR

Name of substation	ID	Name of feeder	Total Loss	Capacitor placement			
			Before	Loss	Fixed	Switch	Savings Loss
			kW	kW	Unit	Unit	kW
Phonethong	1	MSS 5.1	230.30	188.80	6	7	41.50
	2	MSS 5.2	299.20	245.90	6	4	53.40
	3	MSS 5.3	342.50	264.10	3	9	78.40
	4	MSS 5.4	128.10	105.50	3	6	22.60
	5	MSS 5.5	5.80	5.30	-	2	0.40
	6	MSS 5.6	57.70	45.90	1	5	11.80
Naxaythong	7	MSS10.1	2.30	2.30	-	-	-
	8	MSS10.2	326.70	258.90	5	3	67.90
	9	MSS10.3	1,191.90	850.80	4	3	341.10
	10	MSS10.4	25.90	21.00	3	1	4.90
Tha Ngon	11	MSS8.1	204.80	168.20	2	2	36.60
	12	MSS8.2	187.30	151.40	3	3	35.90
	13	MSS8.3	47.50	40.10	1	2	7.40
	14	MSS8.4	0.20	0.20	-	-	-
Koksa-at	15	MSS 9.1	128.10	102.70	1	4	25.30
	16	MSS 9.2	372.30	287.50	1	4	84.80
	17	MSS 9.3	2,099.90	1,506.90	6	7	593.00
	18	MSS 9.4	218.90	181.30	3	5	37.60
	19	MSS 9.5	16.80	14.30	2	2	2.40
	20	MSS 9.6	24.00	19.60	2	4	4.40
Thanaleng	21	MSS 6.1	222.80	186.60	1	5	36.20
	22	MSS 6.2	1.20	1.20	-	-	-
	23	MSS 6.4	1.30	1.30	-	-	-
	24	MSS 6.5	82.20	68.10	1	3	14.20
	25	MSS 6.6	476.00	406.80	2	4	69.20
	26	MSS 6.7	410.70	332.80	5	5	77.90
	27	MSS 6.8	239.70	189.50	4	4	50.20
Sokphalaung	28	MSS 1.1	18.10	14.40	2	3	3.70
	29	MSS 1.2	51.70	40.70	3	5	11.00
	30	MSS 1.3	19.20	15.50	2	2	3.70
	31	MSS 1.4	0.70	0.60	1		0.10
	32	MSS 1.5	38.00	31.70	4	2	6.30
	33	MSS 1.6	15.80	13.00	4	2	2.80

Table 5.27 Summarize result from program of capacitor bank 100kVAR (Continued)

Name of substation	ID	Name of feeder	Total Loss	Capacitor placement			
			Before	Loss	Fixed	Switch	Savings Loss
			kW	kW	Unit	Unit	kW
Sisakhet	34	MSS2.1	29.20	24.00	3	4	5.20
	35	MSS2.2	18.10	14.50	2	5	3.60
	36	MSS2.3	5.50	4.50	2	2	1.00
	37	MSS2.4	0.20	0.10	1	-	0.00
	38	MSS2.5	12.80	10.10	1	3	2.60
	39	MSS2.6	53.10	42.80	3	5	10.20
Thatlaung	40	MSS3.1	108.50	86.30	3	4	22.20
	41	MSS3.2	20.20	16.80	2	3	3.40
	42	MSS3.3	18.30	15.10	2	3	3.20
	43	MSS3.4	37.20	30.10	3	2	7.10
Dongnasok	44	MSS4.1	288.40	239.00	6	3	49.40
	45	MSS4.2	1,288.40	1,030.10	16	3	258.30
	46	MSS4.3	88.80	73.10	3	5	15.60
	47	MSS4.4	4.80	4.20	-	1	0.60
Total			9,460.60	7,353.50	128	151	2,107.10

Table 5.27 can be summarized as following: the fixed capacitors bank installed 128 units, 300 kVAR per unit and 5.5 USD/ kVAR. The switched capacitors bank installed 151 units, 300 kVAR per unit and 10 USD/ kVAR. Total loss is 9,460.60 kW before installing capacitors bank and 7,353.50 kW after installing capacitors bank. It decreases 2,107.10 kW

5.6.2.3 Capacitor bank at 200 kVAR per phase

Table 5.28 Summarize result from program of capacitor bank 200kVAR

Name of substation	ID	Name of feeder	Total Loss	Capacitor placement			
			Before	Loss	Fixed	Switch	Savings Loss
			kW	kW	Unit	Unit	kW
Phonethong	1	MSS 5.1	230.30	190.40	3	3	39.80
	2	MSS 5.2	299.20	246.50	3	2	52.70
	3	MSS 5.3	342.50	264.10	1	5	78.40
	4	MSS 5.4	128.10	107.60	1	3	20.50
	5	MSS 5.5	5.80	5.40	-	1	0.40
	6	MSS 5.6	57.70	46.10	-	3	11.60
Naxaythong	7	MSS10.1	2.30	2.30	-	-	-
	8	MSS10.2	326.70	270.70	2	1	56.00
	9	MSS10.3	1,191.90	881.40	2	1	310.60
	10	MSS10.4	25.90	21.00	1	1	4.90

Table 5.28 Summarize result from program of capacitor bank 200kVAR (Continued)

Name of substation	ID	Name of feeder	Total Loss	Capacitor placement			
			Before	Loss	Fixed	Switch	Savings Loss
			kW	kW	Unit	Unit	kW
Tha Ngon	11	MSS8.1	204.80	168.10	1	1	36.70
	12	MSS8.2	187.30	151.70	1	2	35.60
	13	MSS8.3	47.50	42.50	-	1	5.00
	14	MSS8.4	0.20	0.20	-	-	-
Koksa-at	15	MSS 9.1	128.10	102.80	-	3	25.30
	16	MSS 9.2	372.30	297.20	-	2	75.10
	17	MSS 9.3	2,099.90	1,509.10	3	4	590.70
	18	MSS 9.4	218.90	188.60	1	2	30.30
	19	MSS 9.5	16.80	14.30	1	1	2.40
	20	MSS 9.6	24.00	19.90	1	2	4.20
Thanaleng	21	MSS 6.1	222.80	186.60		3	36.20
	22	MSS 6.2	1.20	1.20	-	-	-
	23	MSS 6.4	1.30	1.30	-	-	-
	24	MSS 6.5	82.20	68.10		2	14.10
	25	MSS 6.6	476.00	408.00	1	2	68.00
	26	MSS 6.7	410.70	333.00	2	3	77.70
	27	MSS 6.8	239.70	189.70	2	2	50.00
Sokphalaung	28	MSS 1.1	18.10	14.80	1		3.20
	29	MSS 1.2	51.70	40.80	1	3	10.90
	30	MSS 1.3	19.20	15.80	1	1	3.50
	31	MSS 1.4	0.70	0.70	-	-	-
	32	MSS 1.5	38.00	31.70	2	1	6.30
	33	MSS 1.6	15.80	13.10	2	1	2.70
Sisakhet	34	MSS2.1	29.20	24.50	1	2	4.70
	35	MSS2.2	18.10	14.90	1	2	3.20
	36	MSS2.3	5.50	4.50	1	1	1.00
	37	MSS2.4	0.20	0.10	-	-	-
	38	MSS2.5	12.80	10.20	-	2	2.60
	39	MSS2.6	53.10	42.90	1	3	10.10
Thatlaung	40	MSS3.1	108.50	88.50	1	2	20.00
	41	MSS3.2	20.20	17.30	1	1	2.90
	42	MSS3.3	18.30	15.60	1	1	2.70
	43	MSS3.4	37.20	31.10	1	1	6.10
Dongnasok	44	MSS4.1	288.40	242.80	3	1	45.60
	45	MSS4.2	1,288.40	1,038.60	8	1	249.80
	46	MSS4.3	88.80	73.10	1	3	15.70
	47	MSS4.4	4.80	4.80	-	-	-
Total			9,460.60	7,443.40	53	76	2,017.20

Table 5.28 can be summarized as following: the fixed capacitors bank installed 53 units, 300 kVAR per unit and 5.5 USD/ kVAR. The switched capacitors bank installed 76 units, 300 kVAR per unit and 10 USD/ kVAR. Total loss is 9,460.60 kW before installing capacitors bank and 7,443.40 kW after installing capacitors bank. It decreases 2,017.20 kW.

5.6.2.4 Summarizing of capacitor placement in distribution system of Vientiane capital

The capacitor placement in CYMDIST program had calculated three value of capacitor bank. There are set capacitor bank 50 kVAR, 100 kVAR and 200kVAR per phase. The results in above could summarize as seen table 5.29.

Table 5.29 Summarize installation capacitor bank at 50 kVAR, 100kVAR and 200 kVAR per phase in distribution system.

Name of substation	Total Loss	Capacitor bank at 50 kVAR/phase			Capacitor bank at 100 kVAR/phase			Capacitor bank at 200 kVAR/phase		
	Before	Fixed	Switch	Savings Loss	Fixed	Switch	Savings Loss	Fixed	Switch	Savings Loss
	kW	Unit	Unit	kW	Unit	Unit	kW	Unit	Unit	kW
Phonethong	1063.60	42	63	209.30	19	33	208.10	8	17	203.40
Naxaythong	1546.80	27	14	427.00	12	7	413.90	5	3	371.50
Tha Ngon	439.80	15	13	82.60	6	7	79.90	2	4	77.30
Koksa-at	2860.00	33	59	641.80	15	26	747.50	6	14	728.00
Thanaleng	1433.90	30	43	257.10	13	21	247.70	5	12	246.00
Sokphalaung	143.50	36	30	28.80	16	14	27.60	7	6	26.60
Sisakhet	118.90	28	38	23.20	12	19	22.60	4	10	21.60
Thatlaung	184.20	22	23	36.40	10	12	35.90	4	5	31.70
Dongnasok	1670.40	51	24	327.10	25	12	323.90	12	5	311.10
Total	9,461.10	284	307	2,033.30	128	151	2,107.10	53	76	2,017.20

5.6.3 Switching optimization

5.6.3.1 Sokphalaung substation Switching Optimization Report

Sokphalaung substation have six feeders, the name of feeders are MSS1.1, MSS1.2, MSS1.3 MSS1.4, MSS1.5 MSS1.6 shown as figure 5.9




Figure 5.9 Location of DS connected point feeders of Sokpalaung substation

Table 5.30 Switching operations of Sokpalaung substation

Section Id	Action	Switch Id	Load transferred			Losses
			From	To	kW	kW
S1_F2_92	Open	S1_F2_92				143.50
S1_F2_98	Close	S1_F2_98	MSS1_2	MSS1_3	616.00	139.40
S1_F2_52	Open	S1_F2_52				137.40
S1_F2_61	Close	S1_F2_61	MSS1_2	MSS1_3	276.00	137.40
S1_F2_24	Open	S1_F2_24				136.00
S1_F2_148	Close	S1_F2_148	MSS1_2	MSS1_2	3,591.00	136.00

Table 5.31 Network summary of Sokpalaung substation

Feeder Id	Capacity	Initial load	Final load	Initial losses	Final losses	Initial length	Final length
	MVA	MVA	MVA	kW	kW	km	km
MSS1_1	14.20	6.50	6.50	18.10	18.10	5.00	5.00
MSS1_2	14.60	8.70	7.60	51.70	37.10	11.00	10.10
MSS1_3	14.60	5.60	6.60	19.20	26.30	10.80	11.70
MSS1_4	20.50	2.00	2.00	0.70	0.70	1.90	1.90
MSS1_5	14.60	8.00	8.00	38.00	38.00	12.90	12.90
MSS1_6	14.60	7.60	7.60	15.80	15.80	6.70	6.70

Table 5.32 System losses of Sokphalaung substation

Initial Losses	Final losses	Savings losses		
kW	kW	kW	%	USD/year
143.48	135.99	7.49	5.22	0




Figure 5.10 Location of DS connected point feeders of Sokpalaung substration

5.6.3.2 Sisakhet substation Switching Optimization Report

Sisakhet substation have six feeders, the name of feeders are MSS2.1, MSS2.2, MSS2.3 MSS2.4, MSS2.5 MSS2.6 shown as figure 5.11




Figure 5.11 Location of DS connected point feeders of Sisakhet substation

Table 5.33 a. Switching operations of Sisakhet substation

Section Id	Action	Switch Id
S2_F2_29	Close	S2_F2_29
S2_F2_76	Close	S2_F2_76
S2_F3_38	Open	S2_F3_38
S2_F2_73 -1	Open	S2_F2_73-1

b. Network summary of Sisakhet substation

Feeder Id	Capacity	Initial load	Final load	Initial losses	Final losses	Initial length	Final length
	MVA	MVA	MVA	kW	kW	km	km
MSS2_2	14.60	8.60	8.90	18.10	18.80	3.80	4.00
MSS2_3	14.60	5.20	4.90	5.50	4.80	2.70	2.60

c. System losses of Sisakhet substation

Initial losses	Final losses	Savings losses		
kW	kW	kW	%	USD/year
23.64	23.59	0.05	0.21	0

5.6.3.3 Thatlaung substation switching optimization report

Figure 5.13 Location of DS connected point feeders of Thatlaung substation

Table 5.34 a. Switching operations of Thatlaung substation

Section Id	Action	Switch Id
S3_F1_68	Close	S3_F1_68
S3_F4_139	Close	S3_F4_139
S3_F4_160	Close	S3_F4_160
S3_F3_75	Close	S3_F3_75
S3_F1_136	Open	S3_F1_136
S3_F1_20	Open	S3_F1_20
S3_F1_108	Open	S3_F1_108
S3_F2_52	Open	S3_F2_52

b. Network summary of Thatlaung substation

Feeder	Capacity	Initial load		Final load		Initial losses	Final losses	Initial length	Final length
Id	kVA	kVA	%	kVA		kW	kW	km	km
MSS3.1	20,459.90	8,110.50	39.64	7,116.10	34.78	108.50	75.24	62.12	38.72
MSS3.2	14,614.20	6,853.20	46.89	5,866.20	40.14	20.15	14.21	6.17	5.75
MSS3.3	14,614.20	6,721.40	45.99	7,705.20	52.72	18.32	22.37	5.79	6.21
MSS3.4	14,614.20	6,589.70	45.09	7,578.80	51.86	37.16	59.49	16.32	39.70

c. System losses of Thatlaung substation

Initial losses	Final losses	Savings losses		
kW	kW	kW	%	USD/year
184.13	171.31	12.82	6.96	0

5.6.3.4 Dongnasok substation switching optimization report

Dongnasok substation have four feeders, the name of feeders are MSS4.1, MSS4.2, MSS4.3 and MSS4.4, shown as figure 5.14




Figure 5.14 Location of DS connected point feeders of Dongnasok substation

Table 5.35 a. Switching operations of Dongnasok substation

Section Id	Action	Switch Id	Load Transferred			Losses
			From	To	kW	kW
S4_F2_21	Open	S4_F2_21				1,670.10
S4_F2_46	Close	S4_F2_46	MSS4_2	MSS4_3	2,251.00	1,518.70
S4_F2_61	Open	S4_F2_61				1,483.20
S4_F2_66	Close	S4_F2_66	MSS4_2	MSS4_4	311.00	1,483.20
S4_F1_22	Open	S4_F1_22				1,480.10
S4_F1_25	Close	S4_F1_25	MSS4_1	MSS4_4	139.00	1,480.10
S4_F1_30	Open	S4_F1_30				1,445.50
S4_F4_35	Close	S4_F4_35	MSS4_1	MSS4_4	1,531.00	1,445.50
S4_F1_52	Open	S4_F1_52				1,437.90
S4_F4_34	Close	S4_F4_34	MSS4_1	MSS4_4	362.00	1,437.90
S4_F3_30	Open	S4_F3_30				1,435.10
S4_F2_45	Close	S4_F2_45	MSS4_3	MSS4_3	1,998.00	1,435.10

b. Network summary of Dongnasok substation

Feeder Id	Capacity	Initial load	Final load	Initial losses	Final losses	Initial length	Final length
	MVA	MVA	MVA	kW	kW	km	km
MSS4_1	14.60	13.20	10.80	288.30	224.60	24.30	22.40
MSS4_2	7.30	23.60	20.40	1,288.20	1,049.70	26.50	24.30
MSS4_3	14.60	11.90	14.50	88.80	135.70	19.70	21.30
MSS4_4	14.60	2.70	5.30	4.80	24.20	4.50	7.00

c. System losses of Dongnasok substation

Initial losses	Final losses	Savings losses		
kW	kW	kW	%	USD/year
1,670.11	1,435.15	234.96	14.07	0




Figure 5.15 Location of open and close DS connected point feeders of Dongnasok substation

5.6.3.5 Phonthong substation switching optimization report

Phonthong substation have six feeders, the name of feeders are MSS5.1, MSS5.2, MSS5.3, MSS5.4, MSS5.5 and MSS5.6, shown as figure 5.16.




Figure 5.16 Location of DS connected point feeders of Phonthong substation

Table 5.36 a. Switching operations of Phonthong substation

Section Id	Action	Switch Id	Load transferred			Losses
			From	To	kW	kW
S5_F1_10	Open	S5_F1_10				698.40
S5_F1_1000	Close	S5_F1_1000	MSS5_1	MSS5_5	3,354.00	665.60
S5_F3_277	Open	S5_F3_277				646.50
S5_F3_301	Close	S5_F3_301	MSS5_3	MSS5_4	1,826.00	646.50
S5_F4_250	Open	S5_F4_250				620.80
S5_F5_2	Close	S5_F5_2	MSS5_4	MSS5_5	2,155.00	620.80
S5_F2_61	Open	S5_F2_61				612.70
S5_F2_66	Close	S5_F2_66	MSS5_2	MSS5_1	1,050.00	612.70
S5_F5_54	Open	S5_F5_54				611.40
S5_F4_280	Close	S5_F4_280	MSS5_5	MSS5_5	266.00	611.40

b. Network summary of Phonthong substation

Feeder Id	Capacity	Initial load	Final load	Initial losses	Final losses	Initial length	Final length
	MVA	MVA	MVA	kW	kW	km	km
MSS5_1	13.10	12.50	9.90	137.40	113.90	9.90	8.10
MSS5_2	21.80	9.60	8.40	139.10	101.70	18.00	16.40
MSS5_3	13.10	12.30	10.20	251.00	202.10	26.80	23.60
MSS5_4	13.10	8.30	7.90	73.60	73.20	31.40	28.60
MSS5_5	14.00	5.30	11.60	11.40	34.70	6.80	16.30
MSS5_6	21.80	8.60	8.60	85.90	85.90	11.10	11.10

c. System losses of Phonthong substation

Initial losses	Final losses	Savings losses		
kW	kW	kW	%	USD/year
698.35	611.43	86.93	12.45	0




Figure 5.17 Location of open and close DS connected point feeders of Phonthong substation

5.6.3.6 ThaNgon substation switching optimization report

ThaNgon substation have four feeders, the name of feeders are MSS8.1, MSS8.2, MSS8.3 and MSS8.4, shown as figure




Figure 5.18 Location of DS connected point feeders of ThaNgon substation

Table 5.37 a. Switching operations of ThaNgon substation

Section Id	Action	Switch Id	Load transferred			Losses
			From	To	kW	kW
S8_F3_222	Open	S8_F3_222				439.80
S8_F4_16	Close	S8_F4_16	MSS8_3	MSS8_4	830	432.50

b. Network summary of ThaNgon substation

Feeder Id	Capacity	Initial load	Final load	Initial losses	Final losses	Initial length	Final length
	MVA	MVA	MVA	kW	kW	km	km
MSS8_1	13.10	6.00	6.00	204.80	204.80	86.10	86.10
MSS8_2	13.10	7.80	7.80	187.30	187.30	66.30	66.30
MSS8_3	13.10	4.90	3.90	47.50	35.80	75.10	64.40
MSS8_4	20.80	0.30	1.20	0.20	4.70	7.90	18.60

c. System losses of ThaNgon substation

Initial losses	Final losses	Savings losses		
kW	kW	kW	%	USD/year
439.77	432.50	7.27	1.65	0




Figure 5.19 Location of open and close DS connected point feeders of ThaNgon substation

5.6.3.7 Khoksa-at substation switching optimization Report

Khoksa-at substation have six feeders, the name of feeders are MSS9.1, MSS9.2, MSS9.3, MSS9.4, MSS9.5 and MSS9.6, shown as figure




Figure 5.20 Location of DS connected point feeders of Khoksa-at substation

Table 5.38 a. Switching operations of Khoksa-at substation

Section Id	Action	Switch Id	Load transferred			Losses
			From	To	kW	kW
S9_F1_74	Open	S9_F1_74				2,772.50
S9_F4_A	Close	S9_F4_A	MSS9_1	MSS9_4	949	2,760.20

b. Network summary of Khoksa-at substation

Feeder Id	Capacity	Initial load	Final load	Initial losses	Final losses	Initial length	Final length
	MVA	MVA	kVA	kW	kW	km	km
MSS9_1	13.10	7.70	6.60	128.00	83.40	28.86	21.40
MSS9_2	21.80	6.40	6.40	299.60	299.60	90.63	90.60
MSS9_3	21.80	17.90	17.90	2,085.30	2,085.30	212.42	212.40
MSS9_4	14.60	10.70	11.80	218.80	251.10	13.28	20.70
MSS9_5	14.60	6.10	6.10	16.80	16.80	1.13	1.10
MSS9_6	21.80	7.10	7.10	24.00	24.00	23.34	23.30

c. System losses of Khoksa-at substation

Initial losses	Final losses	Savings losses		
kW	kW	kW	%	USD/year
2,772.50	2,760.18	12.31	0.44	0




Figure 5.21 Location of open and close DS connected point feeders of Khoksa-at substation

5.6.3.8 Switching optimization report all feeders

The switching optimization with utilizing the interconnection could mitigate the feeders' peak losses; however, some of the heavily loaded sections were still remained. Some feeders in all substations are connection by DS as seen below.

Table 5.39 a. Switching operations of switching optimization report all feeders

Section Id	Action	Switch Id	Load Transferred			Losses
			From	To	kW	kW
S9_F3_300	Open	S9_F3_300				8,728.80
S6_F5_265	Close	S6_F5_265	MSS9_3	MSS6_5	1,862.00	7,801.10
S6_F6_150	Open	S6_F6_150				7,529.40
S6_F6_226	Close	S6_F6_226	MSS6_6	MSS1_2	3,405.00	7,529.40
S6_F7_99	Open	S6_F7_99				7,358.30
S6_F7_141	Close	S6_F7_141	MSS6_7	MSS1_5	3,330.00	7,358.30

Table 5.39 a. Switching operations of switching optimization report all feeders
(Continued)

Section Id	Action	Switch Id	Load Transferred			Losses
			From	To	kW	kW
S6_F8_193	Open	S6_F8_193				7,272.10
S1_F3_125	Close	S1_F3_125	MSS6_8	MSS1_3	2,441.00	7,272.10
S3_F1_257	Open	S3_F1_257				7,253.40
S6_F4_30	Close	S6_F4_30	MSS3_1	MSS6_4	879.00	7,253.40
S3_F4_160	Open	S3_F4_160				7,242.70
S9_F6_91	Close	S9_F6_91	MSS3_4	MSS9_6	766.00	7,242.70
S8_F1_227	Open	S8_F1_227				7,234.80
S8_F1_240	Close	S8_F1_240	MSS8_1	MSS9_1	132.00	7,234.80
S6_F1_12	Open	S6_F1_12				7,232.60
S6_F1_13	Close	S6_F1_13	MSS6_1	MSS6_6	372.00	7,232.60
S1_F5_39	Open	S1_F5_39				7,229.70
S1_F5_57	Close	S1_F5_57	MSS1_5	MSS2_5	1,213.00	7,229.70
S3_F1_107	Open	S3_F1_107				7,230.20
S3_F1_108	Close	S3_F1_108	MSS3_1	MSS3_4	461.00	7,230.20
S6_F8_10	Open	S6_F8_10				7,229.90
F6_F6_A	Close	F6_F6_A	MSS6_8	MSS6_6	385.00	7,229.90
S6_F8_261	Open	S6_F8_261				7,229.50

b. Network summary of switching optimization report all feeders

Feeder Id	Capacity	Initial load	Final load	Initial losses	Final losses	Initial length	Final length
	MVA	MVA	MVA	kW	kW	km	km
MSS1_1	14.20	6.50	6.50	18.10	18.10	5.00	5.00
MSS1_2	14.60	7.60	11.50	37.10	147.40	10.10	26.80
MSS1_3	14.60	6.60	9.30	26.30	78.60	11.70	19.90
MSS1_4	20.50	2.00	2.00	0.70	0.70	1.90	1.90
MSS1_5	14.60	8.00	10.80	38.00	107.10	12.90	17.80
MSS1_6	14.60	7.60	7.60	15.80	15.80	6.70	6.70
MSS10_1	20.50	1.20	1.20	2.30	2.30	18.30	18.30
MSS10_2	13.10	9.50	9.50	326.70	326.70	97.60	97.60
MSS10_3	19.10	9.00	9.00	1,183.70	1,183.70	200.60	200.60
MSS10_4	13.10	5.70	5.70	25.90	25.90	24.90	24.90
MSS2_1	14.20	9.90	9.90	29.20	29.20	3.90	3.90
MSS2_2	14.60	8.90	8.90	18.80	18.80	4.00	4.00
MSS2_3	14.60	4.90	4.90	4.80	4.80	2.60	2.60

b. Network summary of switching optimization report all feeders(Continued)

Feeder Id	Capacity	Initial load	Final load	Initial losses	Final losses	Initial length	Final length
	MVA	MVA	MVA	kW	kW	km	km
MSS2_4	14.60	1.80	1.80	0.20	0.20	0.30	0.30
MSS2_5	14.20	4.80	6.20	12.80	26.30	13.20	14.40
MSS2_6	14.20	10.70	10.70	53.10	53.10	10.70	10.70
MSS3_1	20.50	7.10	5.50	75.20	38.60	38.70	25.90
MSS3_2	14.60	5.90	5.90	14.20	14.20	5.70	5.70
MSS3_3	14.60	7.70	7.70	22.40	22.40	6.20	6.20
MSS3_4	14.60	7.60	7.20	59.50	48.70	39.70	22.80
MSS4_1	14.60	10.80	10.80	224.60	224.60	22.40	22.40
MSS4_2	7.30	20.40	20.40	1,049.70	1,049.70	24.30	24.30
MSS4_3	14.60	14.50	14.50	135.70	135.70	21.30	21.30
MSS4_4	14.60	5.30	5.30	25.10	25.10	7.00	7.00
MSS5_1	13.10	9.90	9.90	113.90	113.90	8.10	8.10
MSS5_2	21.80	8.40	8.40	101.70	101.7	16.40	16.40
MSS5_3	13.10	10.20	10.20	202.10	202.10	23.60	23.60
MSS5_4	13.10	7.90	7.90	73.20	73.20	28.60	28.60
MSS5_5	14.00	11.60	11.60	34.70	34.70	16.30	16.30
MSS5_6	21.80	8.60	8.60	85.90	85.90	11.10	11.10
MSS6_1	20.80	9.00	8.50	222.80	219.00	15.20	14.20
MSS6_2	20.80	0.90	0.90	1.20	1.20	4.90	4.90
MSS6_4	20.80	0.80	1.80	1.30	9.50	16.70	26.40
MSS6_5	20.80	7.00	9.20	82.20	241.40	41.00	95.40
MSS6_6	20.80	9.90	6.40	476.00	97.50	43.50	28.20
MSS6_7	20.80	12.50	8.40	410.70	160.60	21.40	16.00
MSS6_8	20.80	10.10	6.70	239.70	92.10	31.30	21.80
MSS8_1	13.10	6.00	5.80	204.80	192.30	86.10	79.20
MSS8_2	13.10	7.80	7.80	187.30	187.30	66.30	66.30
MSS8_3	13.10	3.90	3.90	35.80	35.80	64.40	64.40
MSS8_4	20.80	1.20	1.20	4.70	4.70	18.60	18.60
MSS9_1	13.10	6.60	6.70	83.40	87.90	21.40	28.30
MSS9_2	21.80	6.60	6.60	390.80	390.80	101.50	101.50
MSS9_3	21.80	17.90	14.00	2,085.20	998.40	212.80	158.40
MSS9_4	14.60	11.80	11.80	251.10	251.10	20.70	20.70
MSS9_5	14.60	6.10	6.10	16.80	16.80	1.10	1.10
MSS9_6	21.80	7.10	8.00	24.00	34.30	23.30	43.40

C. System losses of switching optimization report all feeders

Initial losses	Final losses	Savings losses		
kW	kW	kW	%	USD/year
8,728.76	7,229.46	1,499.29	17.18	0




Figure 5.22 Location of open and close DS connected point feeders of Khoksa-at substation

5.6.3.9 Summarize of switching optimization in distribution system of Vientiane capital

The switching optimization in CYMDIST program had calculated. The results in above could summarize as seen table 5.40. The result consist 17 case can reduced losses are 1,861.10 kW or 59.14%. The total DS are 66 sets; there were installed DS 33 sets and existing 33 sets.

Table 5.40 Summarize installation switched in distribution system.

	Name of substations	Name of feeders	Switching optimization				
			Initial losses	Final losses	Savings losses		DS
			kW	kW	kW	%	sets
Case1	Sokphalaung	2,3	143.50	136.00	7.50	5.22	6
Case2	Sisakhet	2,3	23.60	23.60	0.10	0.21	4
Case3	Thatlaung	1,2,3,4	184.10	171.30	12.80	6.96	8
Case4	Dongnasok	1,2,3,4	1,670.10	1,435.20	235.00	14.07	12
Case5	Phonthong	1,2,3,4,5	698.40	611.40	86.90	12.45	10
Case6	Tha Ngon	3,4	439.80	432.50	7.30	1.65	2
Case7	Koksa-at	1,4	2,772.50	2,760.20	12.30	0.44	2
Case8	Koksa-at	3	8,728.80	7,801.10	927.70	10.63	2
	Thanaleng	5					
Case9	Thanaleng	6	7,801.10	7,529.40	271.70	3.48	2
	Sokphalaung	2					
Case10	Thanaleng	7	7,529.40	7,358.30	171.10	2.27	2
	Sokphalaung	5					
Case11	Thanaleng	8	7,358.30	7,272.10	86.20	1.17	2
	Sokphalaung	3					
Case11	Thatlaung	1	7,272.10	7,253.40	18.70	0.26	2
	Thanaleng	4					
Case12	Thatlaung	4	7,253.40	7,242.70	10.70	0.15	2
	Koksa-at	6					
Case13	Tha Ngon	1	7,242.70	7,234.80	7.90	0.11	2
	Koksa-at	1					
Case14	Thanaleng	1,6	7,234.80	7,232.60	2.20	0.03	2
Case15	Sokphalaung	1	7,232.60	7,230.20	2.40	0.03	2
	Sisakhet	5					
Case16	Thanaleng	6,8	7,230.20	7,229.90	0.30	0.00	2
Case17	Sokphalaung	3,5	7,229.90	7,229.50	0.40	0.01	2
Total savings losses			88,045.30	86,184.20	1,861.10	59.14	66

5.6.4 Assumptions in the calculations

5.6.4.1 Tariff

EDL has specification the new electricity tariff adjustment from 3/2012 to 12/2017 as seen in Appendix C. The cost of low voltage could average power tariff are 726 kip/kWH or 0.09 USD. Exchange Rate on (12th October 2012, Bank of the Lao P.D.R) US 1 \$ = 7,980.00 Kip) as seen in Appendix E.

5.6.4.2 Depreciation

According to stipulation of Ministry of Finance the assets of power sector have a high depreciation; the period of depreciation is normally from 5 to 13 years. For fixed assets newly put into operation, the depreciation rate of power network is 10% .

5.6.4.3 Operation and Maintenance Cost (O&M)

Equal to 3% of total investment cost.

5.6.4.4 Discount rate

Based on the technical economic norms given, the discount rate of investment projects in energy sector is usually 10%.

5.6.4.5 Economic life of equipments

According to stipulation of Ministry of Finance the assets of power sector and technical economic norms of Ministry of energy and mines, the economic life of equipments and material is normally 25 years.

5.6.5 Analysis results

5.6.5.1 Improving of financial analysis in the cases

Based on the forecasted demand, technical results calculated in the chapter 5, estimated investment costs, and above assumptions, the case are analyzed; the results are tabulated in table 5.41 to 5.47.

5.6.5.1.1 Summarizing economic of load balancing in distribution system

Table 5.41 Summarize saving cost of load balancing in distribution system

Case	Savings losses		Cost	Savings cost	Investment
	kW	MWH	USD/kWH	USD	USD
MSS3.1	0.01	0.09	0.09	7.80	0
MSS8.1	-	-	0.09	-	-
MSS8.2	0.01	0.09	0.09	7.80	0
MSS8.3	-	-	0.09	-	-
MSS9.1	-	-	0.09	-	-
MSS9.2	0.23	2.01	0.09	181.33	0
MSS9.3	13.40	117.38	0.09	10,564.56	0
MSS9.4	0.05	0.44	0.09	39.43	0
MSS10.2	0.03	0.26	0.09	23.65	0
MSS10.3	7.91	69.29	0.09	6,236.24	0
Total	21.64	189.57	0.09	17,060.98	0

5.6.5.2 Economic parameters for capacitor placement

The cost of fixed and switched capacitors, energy price, discount rate and inflation rate are taken from the data collection. From now to 2013, reactive power consumption cost and demand cost are still set to zero, so they are set to zero. These parameters are shown in table 5.2.

Table 5.42 Economic parameter for optimal capacitor placement

Energy price (USD/kWh)	0.09
Reactive energy price (USD/kVARh)	0
Demand cost (USD/kW)	0
Discount rate %	10
Evaluation period (years)	5
Fixed capacitor price (USD/kVAR)	10
Switched capacitor price (USD/kVAR)	15
Maintenance cost for fixed capacitor (USD/kVAR/year)	0.06
Maintenance cost for Switched capacitor (USD/kVAR/year)	0.09

Table 5.43 Summarize savings cost of capacitor bank 50kVAR

Name of substation	Capacitor bank at 50 kVAR/phase						
	Fixed		Switch		Savings Loss		Savings cost
	kVAR	Investment	kVAR	Investment			
		USD		USD	kW	MWH	USD
Phonethong	6,300	63,000	9,450	141,750	209.30	1,833.50	165,012
Naxaythong	4,050	40,500	2,100	31,500	4270	3,740.50	336,647
Tha Ngon	2,250	22,500	1,950	29,250	82.60	723.60	65,122
Koksa-at	4,950	49,500	8,850	132,750	641.80	5,622.20	505,995
Thanaleng	4,500	45,000	6,450	96,750	257.10	2,252.20	202,698
Sokphalaung	5,400	54,000	4,500	67,500	28.80	252.30	22,706
Sisakhet	4,200	42,000	5,700	85,500	23.20	203.20	18,291
Thatlaung	3,300	33,000	3,450	51,750	36.40	318.90	28,698
Dongnasok	7,650	76,500	3,600	54,000	327.10	2,865.40	257,886
Total	42,600	426,000	46,050	690,750	2,033.30	17,811.70	1,603,054

Table 5.44 Summarize savings cost of capacitor bank 100kVAR

Name of substation	Capacitor bank at 100 kVAR/phase						
	Fixed		Switch		Savings Loss		Savings cost
	kVAR	Investment	kVAR	Investment			
		USD		USD	kW	MWH	USD
Phonethong	5,700	57,000	9,900	148,500	208.10	1,823.00	164,066
Naxaythong	3,600	36,000	2,100	31,500	413.90	3,625.80	326,319
Tha Ngon	1,800	18,000	2,100	31,500	79.90	699.90	62,993
Koksa-at	4,500	45,000	7,800	117,000	747.50	6,548.10	589,329
Thanaleng	3,900	39,000	6,300	94,500	247.70	2,169.90	195,287
Sokphalaung	4,800	48,000	4,200	63,000	27.60	241.80	21,760
Sisakhet	3,600	36,000	5,700	85,500	22.60	198.00	17,818
Thatlaung	3,000	30,000	3,600	54,000	35.90	314.50	28,304
Dongnasok	7,500	75,000	3,600	54,000	323.90	2,837.40	255,363
Total	38,400	384,000	45,300	679,500	2,107.10	18,458.20	1,661,238

Table 5.45 Summarize savings cost of capacitor bank 200kVAR

Name of substation	Capacitor bank at 200 kVAR/phase						
	Fixed		Switch		Savings Loss		Savings cost
	kVAR	Investment	kVAR	Investment			
		USD		USD	kW	MWH	USD
Phonethong	4,800	48,000	10,200	153,000	203.40	1,781.80	160,361
Naxaythong	3,000	30,000	1,800	27,000	371.50	3,254.30	292,891
Tha Ngon	1,200	12,000	2,400	36,000	77.30	677.10	60,943
Koksa-at	3,600	36,000	8,400	126,000	728.00	6,377.30	573,955
Thanaleng	3,000	30,000	7,200	108,000	246.00	2,155.00	193,946
Sokphalaung	4,200	42,000	3,600	54,000	26.60	233.00	20,971
Sisakhet	2,400	24,000	6,000	90,000	21.60	189.20	17,029
Thatlaung	2,400	24,000	3,000	45,000	31.70	277.70	24,992
Dongnasok	7,200	72,000	3,000	45,000	311.10	2,725.20	245,271
Total	31,800	318,000	45,600	684,000	2,017.20	17,670.70	1,590,360

Based on the results of the forecasted demand, technical analyses, estimated investment costs, reference data and assumptions; table 5.43 to 5.46 summarizes the results of financial analyses for installation capacitor banks 50kVAR, 100kVAR and 200 kVAR. The results of detailed analyses are given in appendix D. In this table, the IRR are high, because the investments are lower profit, there for IRR >10% and Sisakhet case NPV, IRR and Payback period are minus, because investment more than profit. In three cases, the results of installed capacitor banks at 50kVAR, 100kVAR and 200 kVAR case are feasible with NPV>0, and IRR>10%. However,

the NPV of capacitor banks at 100 kVAR case is higher than 50kVAR and 200 kVAR. The investment cost of installed capacitor banks at 100kVAR is lower than investment cost of 50kVAR, 100kVAR. As a result, payback period capacitor bank at 100kVAR is 0.72 year and the best choice as seen in Appendix D.

Table 5.46 Results of financial analyses of capacitor placement

Name of substation	Capacitor bank at 50 kVAR/phase			Capacitor bank at 100 kVAR/phase			Capacitor bank at 200 kVAR/phase		
	NPV	IRR	Payback period	NPV	IRR	Payback period	NPV	IRR	Payback period
	x10 ⁶ USD	%	year	x10 ⁶ USD	%	year	x10 ⁶ USD	%	year
Phonethong	0.41	75%	1.46	0.40	74%	1.47	0.39	74%	1.47
Naxaythong	1.20	467%	0.23	1.16	483%	0.22	1.05	514%	0.21
Tha Ngon	0.19	123%	0.90	0.19	124%	0.89	0.18	124%	0.89
Koksa-at	1.72	277%	0.40	2.06	363%	0.30	2.00	354%	0.31
Thanaleng	0.62	141%	0.79	0.60	144%	0.77	0.59	138%	0.81
Sokphalaung	0.00	11%	10.78	0.01	12%	10.07	0.03	15%	8.65
Sisakheth	(0.07)	-15%	-	(0.06)	-14%	-	(0.06)	-13%	-
Thatlaung	0.02	18%	3.75	0.02	18%	3.76	0.02	22%	3.49
Dongnasok	0.84	196%	0.57	0.83	197%	0.57	0.80	208%	0.53
Total	4.89	141%	0.79	5.16	154%	0.72	4.96	157%	0.71

5.6.5.3 Results of financial analyses of switching optimization

Table 5.47 summarizes the results of financial analyses for switching optimization. The results of detailed analyses are high profit. The disconnecting switch installed 33 sets. Table 4.7 is shown DS costs 6,000 USD/set. Therefore, the investment cost for DS are 198,000.0 USD. This case can reduce losses are 1,861.10 kW, 16,303,236 kWh and savings cost is 1,467,291 USD. For NPV > 10% and payback period is 0.14 year.

Table 5.47 Results of financial analyses of switching optimization

	Existing DS	Installation DS	Investment	Savings losses		
	set	set	USD	kW	MWH	USD
Case1	3	3	18,000	7.50	65.70	5,913
Case2	2	2	12,000	0.10	0.90	79
Case3	4	4	24,000	12.80	112.10	10,092
Case4	6	6	36,000	235.00	2,058.60	185,274
Case5	5	5	30,000	86.90	761.20	68,512
Case6	1	1	6,000	7.30	63.90	5,755
Case7	1	1	6,000	12.30	107.70	9,697
Case8	1	1	6,000	927.70	8,126.70	731,399
Case9	1	1	6,000	271.70	2,380.10	214,208
Case10	1	1	6,000	171.10	1,498.80	134,895
Case11	1	1	6,000	86.20	755.10	67,960
Case11	1	1	6,000	18.70	163.80	14,743
Case12	1	1	6,000	10.70	93.70	8,436
Case13	1	1	6,000	7.90	69.20	6,228
Case14	1	1	6,000	2.20	19.30	1,734
Case15	1	1	6,000	2.40	21.00	1,892
Case16	1	1	6,000	0.30	2.60	237
Case17	1	1	6,000	0.40	3.50	315
Total	33	33	198,000	1,861.10	16,303.2	1,467,291